


Supplier's declaration of conformity

(in accordance with ISO/IEC 17050-1)

1) Number: DARCbus 012017-05
2) Issuer's name: DARC Technologies Limited Issuer's address: 223 Cossars Road, Tai Tapu, Christchurch 7672, New Zealand, www.darctechnologies.com
3) Object of the declaration: DARCbus Dual Relay Driver DTRD10A23 - - 0000 Tested rating includes New Zealand nominal 230 V 50 Hz fixed mains supply connection at 25 °C ambient. Rated input current at 230 V = 10 A Note: the object is designed to be associated with: DARCbus Switch Single white button DTSW10A23 - - 010GWH DARCbus Switch 3 Button Black DTSW10A23 - - 030GBK
4) The object of the declaration described above is in conformity with the requirements of the following documents: AS/NZS 60669.2.1:2013 (IEC 60669-2-1 2009-01 Ed 4.1 mod) Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches in conjunction with AS/NZS 60669.1:2013 (IEC 60669-1 2007-01 Ed 3.2 mod) Switches for households and similar fixed-electrical installations – Part 1: general requirements (The documents listed above are the same and/or more recent amended editions of the documents listed in the Electricity (Safety) Regulations 2010 Schedule 4 (Reprint as at 1 February 2016) or AS/NZS 4417.2:2012 incorporating A1 and A2)
5) Supporting Documentation: PowerLab Limited, Test Report PL1514-7-Relay, January 2017
6) Additional information: Not applicable.
7) Signed for and on behalf of: Place and date of issue: 20 December 2016, Christchurch New Zealand Dennis Chapman, Technical Director  (Name, function) (Signature or equivalent authorized by the issuer)