

## Supplier's declaration of conformity

(in accordance with ISO/IEC 17050-1)

**1) Number: DARCbus 012017-05**

**2) Issuer's name:**

DARC Technologies Limited

Issuer's address:

17 Print Place, Christchurch 8024, New Zealand, DARCTechnologies.com

**3) Object of the declaration:**

DARCbus Dual Relay Driver DTRD10A23 - - 0000

Tested rating includes New Zealand nominal 230 V 50 Hz fixed mains supply connection at 25 °C ambient.

Rated input current at 230 V = 10 A

Note: the object is designed to be associated with:

DARCbus Switch Single white button DTSW10A23 - - 010GWH

DARCbus Switch 3 Button Black DTSW10A23 - - 030GBK

**4) The object of the declaration described above is in conformity with the requirements of the following documents:**

AS/NZS 60669.2.1:2013 (IEC 60669-2-1 2009-01 Ed 4.1 mod) Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches in conjunction with AS/NZS 60669.1:2013 (IEC 60669-1 2007-01 Ed 3.2 mod) Switches for households and similar fixed-electrical installations – Part 1: general requirements

(The documents listed above are the same and/or more recent amended editions of the documents listed in the Electricity (Safety) Regulations 2010 Schedule 4 (Reprint as at 1 February 2016) or AS/NZS 4417.2:2012 incorporating A1 and A2)

**5) Supporting Documentation:**


PowerLab Limited, Test Report PL1514-7-Relay, January 2017

**6) Additional information:** Not applicable.

**7) Signed for and on behalf of:**

Place and date of issue: 20 December 2016, Christchurch New Zealand

**Robert Stuart, Engineer**



(Name, function)

(Signature or equivalent authorized by the issuer)