


Supplier's declaration of conformity

(in accordance with ISO/IEC 17050-1)

1) Number: DARCbus 14122018-06
2) Issuer's name: DARC Technologies Limited Issuer's address: 17 Print Place, Christchurch 8024, New Zealand, DARCTechnologies.com
3) Objects of the declaration: DARCBUS 10 A RELAY DTRD10A23-0300 Tested rating includes New Zealand nominal 230 V 50 Hz, IC and fixed mains supply connection at 50 °C ambient. Rated relay control current at 230 V = 10 A
4) The object of the declaration described above is in conformity with the requirements of the following documents: AS/NZS 60669.2.1:2013 (IEC 60669-2-1 2009-01 Ed 4.1 mod) Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches in conjunction with AS/NZS 60669.1:2013 (IEC 60669-1 2007-01 Ed 3.2 mod) Switches for households and similar fixed-electrical installations – Part 1: general requirements (The documents listed above are the same editions of the documents listed in the Electricity (Safety) Regulations 2010 Schedule 4 (Reprint as at 1 February 2016) or AS/NZS 4417.2:2012 incorporating A1 and A2)
5) Supporting Documentation: PowerLab Limited, Test Report PL1611-6-Relay, dated 14 December 2018
6) Additional information: Not applicable.
7) Signed for and on behalf of: Place and date of issue: 17 December 2018. Christchurch New Zealand Robert Stuart, Engineer  (Name, function) (Signature or equivalent authorized by the issuer)