


## Supplier's declaration of conformity

(in accordance with ISO/IEC 17050-1)

<b>1) Number: DARCbus 18122018-07</b>
<b>2) Issuer's name:</b>  DARC Technologies Limited  Issuer's address:  223 Cossars Road, Tai Tapu, Christchurch 7672, New Zealand, DARCTechnologies.com
<b>3) Objects of the declaration:</b>  DARCBUS 10 A FILTER DTFL10A23-0100  Tested rating includes New Zealand nominal 230 V 50 Hz, fixed mains supply connection at 50 °C ambient and restricted access.  Rated current at 230 V = 10 A
<b>4) The object of the declaration described above is in conformity with the requirements of the following documents:</b>  AS/NZS 60950-1 2011 with Amendment 1 (IEC 60950-1 Edition 2.0 (2005), MOD) Information technology equipment-Safety Part 1: General requirements  Part of clause 8.2.3 of AS/NZS 3439.3:2002.  (The documents listed above are the same editions of the documents listed in the Electricity (Safety) Regulations 2010 Schedule 4 (Reprint as at 1 February 2016) or AS/NZS 4417.2:2012 incorporating A1 and A2)
<b>5) Supporting Documentation:</b>  PowerLab Limited, Test Report PL1611-7-Filter, dated 18 December 2018
<b>6) Additional information:</b> Not applicable.
<b>7) Signed for and on behalf of:</b>  Place and date of issue: 18 December 2018, Christchurch New Zealand  <b>Dennis Chapman, Technical Director</b>  (Name, function) (Signature or equivalent authorized by the issuer)